

Notice of Exemption

To: Office of Planning and Research
1400 Tenth Street
Sacramento, CA 95814

Orange County Clerk Recorder
601 North Ross Street
Santa Ana, CA 92701-0238

From (Applicant/Lead agency):
Orange County Sanitation District
18480 Bandilier Circle
Fountain Valley, CA 92708

Project Title: Digester K Dome Repair at Plant No. 2, Project No. FR2-0032

Project Applicant: Orange County Sanitation District, 18480 Bandilier Cir, Fountain Valley, CA 92708

Project Location (specific): 22212 Brookhurst Street **Cross Street:** Bushard Street

Project Location - City: Huntington Beach **Project Location — County:** Orange

Description of Project:

This project will repair Digester K dome. This involves repairing exposed rebar and structural cracks and proper preparation of the dome surface prior to concrete application. The concrete application consists of applying a 2-inch thick polymer concrete over the entire existing Digester K dome,

Name of Public Agency Approving Project: Orange County Sanitation District
18480 Bandilier Cir,
Fountain Valley, CA 92708

Name of Person or Agency Carrying Out Project: Orange County Sanitation District
18480 Bandilier Cir,
Fountain Valley, CA 92708

Exempt Status: (check one)

- Ministerial (Sec. 21080(b)(1); 15268);
 Declared Emergency (Sec. 21080(b)(3); 15269(a));
 Emergency Project (Sec. 21080(b)(4); 15269(b)(c));
 Categorical Exemption. State type and section number: CEQA Guidelines Class 1 § 15301
 Statutory Exemptions. State code number: _____

Reasons why project is exempt: The project is exempt from CEQA under the Class 1 categorical exemptions set forth in California Code of Regulations sections 15301. Section 15301 (Class 1) exempts from CEQA “the operation, repair, maintenance ... or minor alteration of existing public or private structures, facilities ... involving negligible or no expansion of use beyond that existing at the time of the lead agency’s determination” including “(b) Existing facilities of both investor and publicly-owned utilities used to provide electric power, natural gas, sewerage, or other public utility services.”

The project is exempt because it involves repairs of existing facilities involving no expansion of use or capacity.

Lead Agency

Contact Person: Andrew Brown Area Code/Telephone/Extension: (714) 593-7052

Signature: _____ Date: 11/13/24 Title: Engineering Supervisor

Signed by Lead Agency